



City of Huntsville
448 State Highway 75 N
Huntsville, TX 77320
Lucy Gonzalez, CTCD
Procurement Manager
Telephone: (936) 291-5495
Email: purchasing@huntsvilletx.gov

ADDENDUM #1

Title	Bid Number	Closing Date	Issued Date
Sidewalk Repairs	25-37	September 8, 2025, at 2:00 P.M. Central Standard Time	August 26, 2025

TO ALL PROSPECTIVE BIDDERS:

The information contained in this Addendum supersedes information contained in the Contract Documents to the extent indicated. All information contained in the Contract Documents remain in full force and effect unless specifically modified herein. All Respondents shall acknowledge the receipt of the Addendum in the space provided on this Addendum Form and submit this form with your bid packet. Failure to do so will result in Respondent disqualification.

The attention of all prospective Respondents is directed to the following modifications for the above referenced project.

Site Visit

A non-mandatory site visit will be conducted on **Thursday, August 28, 2025, at 10:00 A.M.** at 448 Hwy 75 N (City Service Center).

All who wish to attend may pre-register. Please contact Lucy Gonzalez, Procurement Manager via email: purchasing@huntsvilletx.gov no later than **Wednesday, August 27, 2025, by 2:00 P.M.**

Include:

Bid: Bid NO. 25-37 Sidewalk Repairs

Company Name:

Representative's Name:

Phone Number:

Email:

Questions and Answers

Question No. 1: When is the non-mandatory site visit scheduled for?

Answer: We can schedule for August 28th at 10am. Depart from 448 Hwy 75 N (City Service Center).

Question No. 2: How wide is the 680 LF of sidewalk repairs indicated in the scope of work?

Answer: 4 feet wide

Question No. 3: Will the sidewalk be 4” thick? Is there any base material that will be needed (is the existing sidewalk sinking anywhere)?

Answer: Sidewalk shall be 4" thick. Some fill material may be needed but not a lot.

Question No. 4: Is there access to the area for a concrete truck or will the concrete need to be wheel barrowed to the location of repairs?

Answer: Mixer truck can access the areas from Veterans Memorial.

Question No. 5: I cannot seem to find the location of repairs. Is that possible to get so I can go take a look?

Answer: Yes, all the areas are marked with white paint. All the sidewalk borders Veterans Memorial Blvd.

Please include signed copy of Addendum with submitted Solicitation Packet.

Responder Name: _____

Address: _____

Telephone Number: _____

Printed Name of Contact

Fax Number: _____

Email Address: _____

Authorized Signature